

**Town of Creighton - Drinking Water Quality and Compliance  
Annual Notice to Consumer  
JANUARY 1 – DECEMBER 31, 2021**

**Water Quality Standards**

**Bacteriological Quality**

	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	52	54	0%

**Water Disinfection –**

**Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples**

	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free 0.5 mg/L total	0.51-1.15	0.23-0.94	52	54	0%

**Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-  
From Water Treatment Plant Records**

	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.40	0.42-1.30	365	0

*A minimum of 0.4 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.4 mg/L free chlorine residual.*

**Turbidity – From Water Treatment Plant Records**

NTU not to exceed	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# TESTS Performed
0.3 over 12 Consecutive hrs	0.032-0.196	0	0.196	730	730

**Chemical – Health Category**

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on June 25, 2020.

	Limit MAC(mg/L)	Limit IMAC(mg/L)	Sample Results(mg/L)	# Samples Exceeding Limits
Arsenic	0.025		<0.0010	0
Barium	1.0		<0.0010	0
Boron		5.0	<0.10	0
Cadmium	0.005		<0.000050	0
Chromium	0.05		<0.0010	0
Lead	0.01		<0.00050	0
Selenium	0.01		<0.00050	0
Uranium	0.02		<0.00010	0
Mercury	0.001		<0.0000050	0
Cyanide	0.2		<0.0010	0

**Trihalomethanes (THMs) / Haloacetic Acid (HAA)**

THM / HAA Limit(mg/L)	Samples Results (average) (mg/L)	# Samples Required	# Samples Submitted
0.100 / 0.080	0.076/0.047	4	4

**General Chemical**

	Aesthetic Objectives (mg/L)	Samples Results (average)(mg/L)	# Samples Required	#Samples Submitted	#Samples Exceeding Limits
Alkalinity	500	44.9	4	4	0
Bicarbonate	None	50.0	4	4	0
Carbonate	None	<0.60	4	4	0
Chloride	250	26.43	4	4	0
Conductivity	None (uS/cm)	183	4	4	0
Hardness	800	61.4	4	4	0
Nitrate	45 MAC	0.18	4	4	0
Magnesium	200	3.34	4	4	0
PH	6.5 – 9.0	7.44	4	4	0
Sodium	300	11.0	4	4	0
Sulphate	500	5.2	4	4	0
Fluoride	1.5 MAC	0.48	4	4	0
Total dissolved Solids	1500	92.6	4	4	0

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once every three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids. The last sets of quarterly samples for General Chemical analysis were submitted on .. 01/02/21

**More information on water quality and sample submission performance may be obtained from:**

Paula Muench, Administrator : Town of Creighton; P.O. Box 100; Creighton SK. S0P 0A0  
Telephone: (306) 688-8253; Fax: (306) 688-4764